



CONCRETE THRUST BLOCK SCHEDULE

(BEARING AREA OF THRUST BLOCKS IN SQUARE FEET)

FITTING SIZE (INCHES)	90° BEND, TEE, OR PLUGGED CROSS	45° BEND	22 1/2° BEND	11 1/4° BEND
4	01.9	01.3	--	--
6	04.0	02.1	01.3	--
8	07.1	03.9	02.0	01.3
12	16.0	08.8	04.5	02.3
16	28.4	15.5	08.0	04.0
24	64.0	34.9	18.1	09.1

ABOVE BEARING AREAS BASED ON TEST PRESSURE OF 150 P.S.I. AND AN ALLOWABLE SOIL BEARING STRENGTH OF 1500 POUND PER SQUARE FOOT. TO COMPUTE BEARING AREAS FOR DIFFERENT TEST PRESSURES AND SOIL BEARING STRESSES, USE THE FOLLOWING EQUATION

$$\text{BEARING AREAS} = (\text{TEST PRESSURE}/150) \times (1500/\text{SOIL BEARING STRESS}) \times (\text{TABLE VALUE})$$

NOTES:

1. CONCRETE THRUST BLOCKS NOT PERMITTED UNLESS APPROVED BY CITY ENGINEER
2. STRADDLE BLOCKS REQUIRED WHERE LINES MAY BE EXTENDED IN FUTURE SEE DETAIL NO. 561
3. CONCRETE THRUST BLOCKING TO BE POURED AGAINST UNDISTURBED EARTH.
4. KEEP CONCRETE CLEAR OF JOINT AND ACCESSORIES.
5. THE REQUIRED THRUST BEARING AREAS FOR SPECIAL CONNECTIONS ARE SHOWN ENCIRCLED ON THE PLANS: e.g. 15 INDICATES 15 SQUARE FEET BEARING AREA REQUIRED.
6. IF NOT SHOWN ON PLANS, REQUIRED BEARING AREAS AT FITTING SHALL BE AS INDICATED ABOVE, ADJUST IF NECESSARY, TO CONFORM TO THE TEST PRESSURE(S) AND ALLOWABLE SOIL BEARING STRESS(ES) STATED IN THE SPECIAL PROVISIONS.
7. BEARING AREAS AND SPECIAL BLOCKING DETAILS SHOWN ON PLANS TAKE PRECEDENCE OVER BEARING AREAS AND BLOCKING DETAILS SHOWN ON THIS STANDARD DETAIL. BEARING AREA OF THRUST BLOCKS ARE IN SQUARE FEET.



CITY OF TIGARD
OREGON
CAPITAL CONSTRUCTION AND
TRANSPORTATION DIVISION
13125 S.W. HALL BLVD.
TIGARD, OREGON 97223
VOICE: (503) 639-4171
FAX: (503) 684-7297

APPROVED BY:
AGUSTIN P. DUENAS, P.E.

CITY ENGINEER

JULY 2009

APPROVAL DATE

STANDARD THRUST BLOCK

NO SCALE

DWG. NO.

560