



NOTES:

1. VENT PIPING TO BE GALV.
2. SLOPE COPPER TUBE FROM MAIN UP TO AIR VALVE 1% MIN.
3. CONTACT WATER DEPARTMENT FOR ACCEPPTABLE DEVICES.
4. PROVIDED & INSTALLED BY CONTRACTOR.



CITY OF TIGARD
 OREGON
 CAPITAL CONSTRUCTION AND
 TRANSPORTATION DIVISON
 13125 S.W. HALL BLVD.
 TIGARD, OREGON 97223
 VOICE: (503) 639-4171
 FAX: (503) 684-7297

APPROVED BY:
AGUSTIN P. DUENAS, P.E.
 CITY ENGINEER
 JULY 2009
 APPROVAL DATE

**2" COMBINATION
 AIR & VACUUM VALVE**

NO SCALE
 DWG. NO.
591